

# Bench and Pilot Scale Testing of Aerobic Biological and Advanced Oxidation Process Treatment Methods for Chlorinated Constituents and 1,4-Dioxane in Steam Enhanced Extraction Condensate

## Overview

### Treatment Evaluation Summary

Steam enhanced extraction (SEE) is a proven remedial technology for dense non-aqueous phase liquid (DNAPL) and volatile organic compound (VOC) contaminated sites. SEE was evaluated for in situ source treatment at a former chemical manufacturing facility in Mississippi. The evaluation included extensive treatment testing of groundwater and condensate which would be generated as a result of SEE source reduction operations.

### Site Description/Background


- Former specialty chemicals and adhesives manufacturing plant in Moss Point, MS
- Constituents of primary concern include:
  - 1,2-dichlorethane (1,2-DCA)
  - 1,4-dioxane
  - 2-chloroethanol
  - bis(2-chloroethoxy)methane (BCEM)
  - bis(2-chloroethyl)ether (BCEE)
- An interim measure groundwater treatment system (GWTS) treats recovered groundwater for iron (aeration/pH adj) and 1,2-DCA (GAC)
- SEE would significantly increase flow rate and concentrations of primary constituents of concern, requiring augmentation of GWTS



Site Location Plan


Parameter	Units	Routine	SEE Operations	Treatment Target
Flow Rate	gpm	50	270	—
1,2-DCA	µg/L	100	23,500	180
1,4-Dioxane	µg/L	150	4,100	150
2-Chloroethanol	µg/L	Low	118,000	1,000
BCEM	µg/L	3,900	43,700	110
BCEE	µg/L	180	310	1.0
COD	mg/L	25	370	—
Iron	mg/L	100	200	—

### Initial SEE GW Treatment Concept\*



## Treatment Testing – GAC

### GAC Isotherm Studies




### Isotherm Test Results Summary

Constituent	Clean Water	Matrix Background	Surrogate SEE GW	
	$K_f$	$K_f$	$K_f$	$K_f$
1,2-DCA	9.2	0.52	7.9	0.46
1,4-Dioxane	1.3	0.59	0.89	0.54
2-Chloroethanol	0.52	0.69	0.28	0.76
BCEM	54	0.35	32	0.40
BCEE	28	0.61	18	0.54

- General GAC adsorptive capacity established for the primary constituents of concern
- Significant matrix/competitive adsorption effects observed

### GAC Column Studies



### Column Test Results Summary

Constituent	Estimated GAC Utilization (lb/yr)
1,2-DCA (Governs)	2,800,000
BCEM	1,000,000


- General dosing requirements were established to attain target level of removal for 1,4-dioxane
- UV/peroxide provided better removal in spiked GWTS effluent, but was more susceptible to inhibition due to greatly increased organic loading associated with actual SEE GW

## Treatment Testing – AOP


### Test Water

Study	Water	Compound Mix	Concentration (µg/L)
Bench-Scale (Xylem-Wedeco)	GWTS Effluent (Spiked)	1,4-Dioxane 1,2-DCA 2-Chloroethanol	5,000 3,500 3,500
Pilot-Scale	Pilot SEE GW	SEE Operations Characteristics	

### UV/Peroxide



### Ozone/Peroxide



### Conclusions – AOP Testing

- General dosing requirements were established to attain target level of removal for 1,4-dioxane
- UV/peroxide provided better removal in spiked GWTS effluent, but was more susceptible to inhibition due to greatly increased organic loading associated with actual SEE GW



## Testing and Results – Aerobic Biological Treatment

### Bioreactor Overview

Reactor ID	Type	Volume (L)	SRT (d)	HRT (d)
Test	SBR	4	20	4
Mother	Fill-and-Draw	16	20	20




### Test Bioreactor Performance





### Percent of Influent Mass Attributable to Removal by Biological Reaction

Compound	1,2-DCA	1,4-Dioxane	2-Chloroethanol	BCEM	BCEE
Percent	77	8.0	> 99	> 99	> 87



### AOP Testing of Biologically Treated Effluent



### Conclusions – Aerobic Biological Treatment

- Removed a majority of SEE GW bulk organic content and individual constituents (including BCEM)
- AOP inhibition which was observed during pilot testing of SEE GW was eliminated
- Biological removal of 1,2-DCA and BCEM would reduce GAC consumption substantially (90% or greater)